



**INSPECTION OFFICER ORDER NO. RRW - 001 - 2015**

IN THE MATTER OF THE *NATIONAL ENERGY BOARD ACT*, AN ORDER UNDER SECTION 51.1

\_\_\_\_\_  
Full name of the recipient

is employed by Westcoast Energy Inc., carrying on Business as Spectra Energy Transmission (Westcoast), and/or is a person with management responsibilities and oversight of facility operations.

On 18 June 2015, the undersigned *National Energy Board* Inspection Officer conducted an inspection of Kobes Creek Booster Station.

The Inspection Officer has reasonable grounds to believe: there exists a potentially serious hazard and threat to the safety of workers at the Kobes compressor station as Westcoast has not demonstrated that the overhead cranes are safe to operate.

*Based on the above, the inspection officer has reasonable grounds to believe that a hazard to the safety or security of the public, or employees of a company or a detriment to property or the environment is being or will be caused by the construction, operation, maintenance or abandonment of the pipeline, or excavation activity or construction of a facility as per paragraph 49(2)(a).*


Therefore, \_\_\_\_\_ is HEREBY ORDERED,

pursuant to section 51.1 and subsection 51.1(2) of the *National Energy Board Act*, to

- take measures specified below for guarding the safety or security of the public or employees or protecting property or the environment
- Suspend work until the hazard or detrimental situation has been remedied to the satisfaction of the inspection officer; or the order is stayed or rescinded by the Board

Specified Measures:

Westcoast is ordered to cease use of all overhead cranes with mismatching hoist, trolley and bridge load ratings at the Kobes Creek Booster Station until they can demonstrate they are safe to operate.

Inspection Officer	2646	 Signature
	IO Designation #	
	19 June 2015	
	Date	
517 10th Avenue SW Calgary AB T2R 0A8		